


Kinetico 2040s OD



System Components

Media Vessel (qty) Size (2) 8 x 17"
 Media Vessel Construction Fiberglass Wrapped Engineered Plastic
 Empty Bed Volume 0.40 ft³
 Media Type Fine Mesh Cation Resin
 Media Volume 0.40 ft³
 Bed Depth Packed
 Free Board None
 Riser Tube 1" ABS
 Distributor Upper 0.009" Slots, Engineered Plastic Basket
 Lower 0.009" Slots, Stainless Steel Flat Plate
 Under bedding None
 Regeneration Control Non-electric Use Meter
 Regeneration Type Countercurrent
 Meter Type 0.3 - 25.00 gpm Polypropylene Turbine

Inlet Water Quality

Pressure Range 15 – 125 psi Dynamic Pressure
 Temperature Range 35 – 120° F
 pH Range 5 – 10 SU
 Free Chlorine Cl₂ (Max.) 2.0 mg/L
 Hardness as CaCO₃ (Max.) 44 gpg

Operating Specs

Flow Range (15 / 30 psig) 11.0 - 15.0 gpm
 Flow Configuration Overdrive
 Dimensions (width x depth x height) 17 x 8 x 23"
 Weight (Operating / Shipping) 120 / 90 lbs.

Connections



Inlet / Outlet Connections Custom Adapter and Bracket
 Drain Connection 0.5" Tube
 Brine Line Connection 0.375" Tube
 Power None

System Part Numbers

Kinetico 2040s OD, 18 x 35 brine tank 11125
 Kinetico 2040s OD, 12 x 16 x 20 brine tank 11120
 Kinetico 2040s OD, K-Spray 11127
 Kinetico 2040s OD, no brine tank 11121

Brine Tank Options

Tank Description	K-Spray	12 x 40	12 x 16 x 20	18 x 35
Brine Tank Part Number	9763A	1479B	7202	7938
Tank Height	35"	40"	20"	35"
Tank Footprint	18" DIA	12" DIA	12 x 16"	18" DIA
Material	HDPE	HDPE	HDPE	HDPE
Salt Capacity	200 lbs.	100 lbs.	50 lbs.	250 lbs



Regeneration Specifications

Regeneration Volume 7 gallons
 Regeneration Time 11 minutes
 Backwash Flow Control 1.40 gpm
 Brine Refill Flow Control 0.40 gpm

Setting	Capacity	Efficiency	Dosing	Meter Disc
1.0 lbs.	5,222 grains	5,222 gr./lb.	2.5 lbs./ft ³	
Gallons/Regeneration:				

Disc Selection

(Compensated Hardness*)

1	2	3	4	5	6	7	8
7	15	21	27	31	36	40	44
657	329	219	164	131	109	94	82

*Compensated hardness in gpg = Hardness + (3 x Fe in mg/L)

Operating Profile

Softener shall remove hardness to less than 1/2 gpg when operated in accordance with the operating instructions. The system shall include two tanks. This duplex configuration shall operate with both tanks on-line during service. During regeneration cycles, one tank shall provide water to service and to the regenerating tank. A water meter shall initiate system regeneration. The water meter shall measure the processed volume and be adjustable. Service flow shall be upflow and regeneration flow shall be downflow.

Regeneration Control Valve

The regeneration control valve shall be top mounted (top of media tank), and manufactured from non-corrosive materials. Control valve shall not weigh more than four pounds. Control valve shall provide service and regeneration control for two media tanks. Inlet and outlet ports shall accept a quick connect, double O-ring sealed adapter. Interconnection between tanks shall be made through the regeneration valve with a quick connect adapter. Control valve shall operate using a minimum inlet pressure of 15 psi. Pressure shall be used to drive all valve functions. No electric hook-up shall be required. Control valve shall incorporate four operational cycles including; service, brine draw, slow rinse, and a combined fast rinse and brine refill. Service cycle shall operate in an upflow direction. The brine cycle shall flow downflow, opposite the service flow, providing a countercurrent regeneration. Control valve shall contain a fixed orifice eductor nozzle and self-adjusting backwash flow control. The control valve will prevent the by-pass of hard water to service during the regeneration cycle.

Media Tanks

The tanks shall be designed for a maximum working pressure of 125 psi and hydrostatically tested at 300 psi. Tanks shall be made of engineered plastic with a 2.5 in. threaded top opening. Each tank shall be NSF approved. Upper distribution system shall be of a slot design. Lower distribution system shall be of a flat plate design. Distributors will provide even flow of regeneration water and the collection of processed water.

Conditioning Media

Each softener shall include fine mesh cation resin having a minimum exchange capacity of 40,000 grains/ft³ when regenerated with 15.0 lbs/ft³. The media shall be solid, of a proper particle size and shall contain no plates, shells, agglomerates or other shapes, which might interfere with the normal function of the water softener.

Brine System

A combination salt storage and brine production tank shall be manufactured of corrosion resistant, plastic. The brine tank shall have a chamber to house the brine valve assembly. The brine float assembly shall allow for adjustable salt settings and shall provide for a shutoff to the brine refill. The brine tank shall include a safety overflow connection to be plumbed to a suitable drain.