

Kinetico 4060s OD (Carbon)

System Components

Upper Media Vessel (qty) Size..... (2) 8 x 17"
 Vessel Construction..... Fiberglass Wrapped Engineered Plastic
 Bed Volume (empty / media) 0.40 ft³ / 0.25 ft³
 Media Type Acid Washed Carbon
 Lower Media Vessel (qty) Size..... (2) 8 x 24"
 Vessel Construction..... Fiberglass Wrapped Engineered Plastic
 Bed Volume (empty / media) 0.70 ft³ / 0.70 ft³
 Media Type Fine Mesh Cation Resin
 Riser Tube..... 1" ABS
 Distributor Upper..... 0.014" Slots, ABS Basket
 Lower..... 0.014" Slots, ABS Basket
 Regeneration Control..... Non-electric Use Meter
 Regeneration Type..... Countercurrent
 Meter Type..... 0.3 - 25.00 gpm Polypropylene Turbine

Inlet Water Quality

Pressure Range 25 – 125 psi Dynamic Pressure
 Temperature Range 35 – 120° F
 pH Range 5 – 10 SU
 Free Chlorine Cl₂ (Max.) 2.0 mg/L
 Hardness as CaCO₃ (Max.) 31 gpg

Operating Specs

Flow Range (15 / 30 psig) 11.5- 18.0 gpm
 Flow Configuration Overdrive
 Dimensions (width x depth x height) 17 x 8 x 48"
 Weight (Operating / Shipping)..... 200 / 160 lbs.

Connections

Inlet / Outlet Connections..... Custom Adapter and E-Clip
 Drain Connection 0.50" Tube
 Brine Line Connection..... 0.375" Tube
 Power None

System Part Numbers

Kinetico 4060s OD (Carbon), 18 x 35 brine tank 11215
 Kinetico 4060s OD (Carbon), K-Spray 11216

Brine Tank Options

Tank Description	K-Spray	18 x 35
Brine Tank Part Number	9763	7938
Tank Height	35"	35"
Tank Footprint	18" DIA	18" DIA
Material	HDPE	HDPE
Salt Capacity	200 lbs.	250 lbs


Regeneration Specifications

Regeneration Volume 50 gallons
 Regeneration Time..... 40 minutes
 Backwash Flow Control..... 2.5 gpm
 Brine Refill Flow Control..... 0.25 gpm

Setting	Capacity	Efficiency	Dosing	Meter Disc
3.3 lbs.	11,467 grains	3,475 gr./lb.	4.7 lbs./ft ³	
3.6 lbs.	12,240 grains	3,400 gr./lb.	5.1 lbs./ft ³	
** 4.0 lbs.	13,303 grains	3,326 gr./lb.	5.7 lbs./ft ³	

Gallons/Backwash:

** Settings certified by NSF and or WQA



Disc Selection

(Compensated Hardness*)

1	2	3	4	5	6	7	8
4	8	12	15	18	21	24	26
4	9	13	16	20	23	25	28
5	9	14	18	21	25	28	31
2,168	1,084	723	542	434	361	310	271

*Compensated hardness in gpg = Hardness + (3 x Fe in mg/L)

Kineticco 4060s OD (Carbon)

Operating Profile

Softener shall remove hardness to less than 1 gpg when operated in accordance with the operating instructions. System shall provide continuous softened and filtered water through the use of a quad (four tanks) configuration. This quad configuration shall operate with all tanks on-line during service. During regeneration cycles, one set of tanks (softener and filter) shall provide water to service and to the regenerating tank. A water meter shall initiate system regeneration. The water meter shall measure the processed volume and be adjustable. Service flow shall be downflow through the tanks, and regeneration flow shall be upflow.

Regeneration Control Valve

The regeneration control valve shall be top mounted (top of media tank), and manufactured from non-corrosive materials. Control valve shall not weigh more than four pounds. Control valve shall provide service and regeneration control for two media tanks. Inlet and outlet ports shall accept a quick connect, double O-ring sealed adapter. Interconnection between tanks shall be made through the regeneration valve with a quick connect adapter. Control valve shall operate using a minimum inlet pressure of 15 psi. Pressure shall be used to drive all valve functions. No electric hook-up shall be required. Control valve shall incorporate four operational cycles including; service, brine draw, slow rinse, and a combined fast rinse and brine refill. Service cycle shall operate in a downflow direction. The brine cycle shall flow upflow, opposite the service flow, providing a countercurrent regeneration. Control valve shall contain a fixed orifice eductor nozzle and self-adjusting backwash flow control. The control valve will prevent the by-pass of hard water to service during the regeneration cycle.

Media Tanks

The tanks shall be designed for a maximum working pressure of 125 psi and hydrostatically tested at 300 psi. Tanks shall be made of fiberglass wrapped polyethylene with a 2.5 in. threaded top opening. Each tank shall be NSF approved. Upper and lower distribution system shall be of a slot design. They will provide even distribution of regeneration water and the collection of processed water.

Media

Each unit shall include 0.25 ft³ of acid wash carbon and 0.7 ft³ of Non Solvent Cation Resin

Brine System

A combination salt storage and brine production tank shall be manufactured of corrosion resistant, rotationally molded rigid polyethylene. The brine tank shall have a chamber to house the brine valve assembly. The brine float assembly shall allow for adjustable salt settings and shall provide for a shutoff to the brine refill. The brine tank shall include a safety overflow connection to be plumbed to a suitable drain.